

Annual Drinking Water Quality Report

City of Norman Park

System ID# 0710005

Year 2024

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from Upper Floridian Aquifer, ground water: **We have two wells. Well #101 pumps 125 gallons per minute and Well #102 pumps 350 gallons per minute.**

I'm pleased to report that our drinking water meets federal and state requirements.

If you have any questions about this report or concerning your water, please contact **City of Norman Park at 229-769-3611**. We want our customers to be informed about their water. If you want to learn more, please feel free to contact us during the day at the above number.

City of Norman Park routinely monitors for contaminants in your drinking water according to Federal and State laws. This report is for the period of **January 01 to December 31, 2023**. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Our Source Water Assessment was approved in **August 30, 2000**. Water sources were rated on their susceptibility to becoming polluted. The drinking water supplied to **City of Norman Park** customers is produced from two wells or sources. The potential pollution sources around the **City of Norman Park** wells are as follows:

Well #101 is behind the First Baptist Church near the intersection of US Route 319 and Norman Park Road and has two potential pollution sources (PPS) present in the control zone (15 foot radius) and they are; utility poles and diesel generator. In the management zone (250 foot radius) it has seven potential pollution sources (PPS) and they are; electrical transformers, vehicle parking areas, sewer lines, access and secondary roads, storm water runoff, dumpsters and US Route 319. **Well #102** is located at the intersection of Ellenton – Norman Park Road and Perry Batts Road. In the control zone (25 foot radius) there is one potential pollution sources (PPS) present and it is utility poles. In the management zone (100 foot radius) there are five PPS present and they are; electrical transformers, access and secondary roads, storm water runoff, agricultural fields, and abandoned grain storage silo.

The sources of drinking water (both tap and bottled water) include river, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activity.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. **City of Norman Park** is responsible for providing high quality drinking water, but cannot control the variety of material used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Detected Organic Contaminants Table

Substance	Units	MCL	MCLG	Amount Detected	Range of Detection	Sample Date	Violation	Typical source of contaminant
Chlorine	ppm	4	4	1	1-1	2024	No	Water additive to control microbes

Detected Inorganic Contaminants Table

Substance	Units	MCL	MCLG	Amount Detected	Sample Date	Violation	Typical source of contaminant
Fluoride	ppm	4	4.0	0.4	2024	No	Erosion of natural deposits
Barium	Ppm	2	2	0.097	2024	No	Erosion of natural deposits

Detected Radioactive Contaminants Table

Substance	Units	MCL	MCLG	Amount Detected	Sample Date	Violation	Typical Source of Contaminant
Combined Radium 226/228	pCi/L	5	0	1.19	1/9/2023	No	Erosion of Natural Deposits
Gross Alpha excluding Radon and Uranium	pCi/L	15	0	4.82	1/9/2023	No	

Contaminants that may be present in source water include the following:

Microbial contaminants, such as viruses and bacteria which may come from sewage treatment plants, septic systems, agricultural livestock operation and wildlife.

Inorganic contaminants such as salts and metals, which can be naturally occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemicals contaminants, including synthetic and volatile organic chemicals, which are by products of industrial processes and petroleum production, and can also, come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulation which limits the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protections for the public health.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to the health.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment of other requirements which a water system must follow

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant that is allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbiological contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of disinfectant to control microbiological contaminants.

Please call our office if you have questions.

We at **City of Norman Park** work around the clock to provide top quality water to every person. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

2024 CCR Supplemental Lead and Copper CCR Information For

(GA710005/ Norman Park) Water System

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed) and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Norman Park is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American national Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact Norman Park City Hall at (229) 769-3611. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

Lead and Copper Range Data.

Analyte	Date Sampled	MCLG	Action Level	Range Low High	Units	Violation
Lead	8/1/24	0	15	0 14	ppb	No
Copper	8/1/24	1.3	1.3	.002 .018	ppm	No

The Service Line Inventory (SLI) is a requirement under the Lead and Copper Rule Revisions (LCRR) to help water systems identify and replace lead service line materials to assess the presence of lead and protect public health. The inventory will support proactive lead reduction efforts and ensure compliance with regulatory requirements to minimize lead exposure in drinking water.

To access the SLI for Norman Park, visit: [Norman Park-sumbeltga.hub.arcgis.com](https://normanpark-sumbeltga.hub.arcgis.com).